

Installers Instructions.

9 Volt Battery Powered High Level Alarm / Level Indicator.

The level indicator supplied is Battery operated using smoke alarm logic. This facilitates a far simpler installation, without the need to provide a mains supply to the unit.

- Remove the float switch from packaging and fit the counter weight to the float, approx 300mm up from the red float.
- Lower the float switch into the tank and set at the desired level (recommend about two thirds of the way up the tank). Secure the float switch cable to the eye bolt / bracket provided.
- Fit your cable duct (not Synergy supply) to the turret and run cable to Alarm unit.
- Connect the Black and Brown wires to terminals 1 & 2.
- Set The Switch on the Panel to the Auto Position. Test.

Each alarm unit is tested prior to despatch, to check for correct operation. Please advise the end user to periodically check the battery condition by using the test button on the front of the panel. Once the alarm has been activated the buzzer will sound, and the green light is illuminated. Turn the Switch on the panel to off to silence the buzzer. Empty the tank / investigate the cause for activation. Once the float is lowered i.e. into the off position it will automatically reset.

TURN PANEL BACK ON AND TEST!

It is recommended that a new battery is fitted once a year.
The battery alarm box is not suitable for outdoor use.

**Synergy Wastewater Treatment Products
Croom,
Enmore Road,
Enmore
Bridgwater
Somerset
TA5 2AN
01278 671927**